G75

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No:F.6/DFS/MS/GH/2026/WZ/550 Dated: 04/06/2026

To,

The Commissioner,
Municipal Corporation of Delhi,
S.P.M. Civic Centre, J.L. Nehru Marg,
New Delhi 110002.

Sub: - Regarding renewal of Fire Safety Certificate in r/o M/s Vivah Residency Guest House located at Property No. 25, Bhera Enclave, Paschim Vihar, New Delhi- 110087.

Sir,

This has reference to online application received through MCD portal vide ID- 2026051206696 on the subject cited above. In this connection, it is to inform you that the above said residential building was re-inspected by officer concerned of this department on 25/05/2026 to see the compliance of requisite fire safety measures. Mr. Gaurav was present at the time of inspection. Following shortcoming were observed at the time of inspection.

1. Fire Check door found removed at some places.
2. First aid hose reel nozzle found missing at some places.
3. Carbon monoxide detectors found removed at some places.
4. MOEFA found provided but not functional.
5. P.A. System found provided but not functional.
6. Internal hydrant found provided but not functional.
7. Terrace level pump found provided but not functional.
8. Exit signage's found removed at some places.

In view of above, the application for renewal of Fire Safety Certificate is not considered at this stage & rejected. The occupancy of the building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/ occupier.

Yours Faithfully

02/06/26

S.K. Dua
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. M/s Vivah Residency Guest House located at Property No. 25, Bhera Enclave, Paschim Vihar, New Delhi- 110087
2. MCD Portal ID No. 2026051206699.