GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/2026/School/WZ/ 690 Dated: 17 / 07/2026

To

The Principal
Vivek International School
A-70, Part-5, Karan Vihar,
Delhi-110086

Sub: - Regarding renewal of fire safety certificate in r/o Vivek International School located at A-70, Part-5, Karan Vihar, Delhi-110086.

Sir,

Please refer to your letter no-52026060103307 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 24/06/2026 to check the existing fire safety measures. During inspection it has been observed that the school premise is comprised of ground & 02 upper floor only. At the time of inspection Sh. Mr. Vishvas (Manager) was also present at site. During the course of inspection, the observations/ shortcomings made are as under: -

1. Terrace level fire water tank couldn't be inspected; the inspection ladder is found removed at site.
2. Exit & floors signage's found removed at strategic location in the school premises.
3. Electrical panel installed in stairwell needs to be shifted in a safer place or covered by fire rated door.

Keeping in view of above, renewal of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school premises is at your own risk & responsibility.

Yours faithfully

16/07/26

(S.K. Dua)
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, Zone- XIII, District North West- B (II), Sector-9, Rohini, Delhi – 110085.