c/51

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/EH/2025/SZ/ 417 Dated: 29/10/2025

To,

The Owner/Occupier,
M/s Wok in the Clouds (A Unit of Edesia Hospitality (P) Ltd.),
Flat No. 52, 1st Floor & 2nd Floor, Khan Market,
New Delhi

Subject: -Regarding renewal of Fire Safety Certificate in r/o M/s Wok in the Clouds (A Unit of Edesia Hospitality (P) Ltd.) located at Flat No. 52, 1st Floor & 2nd Floor, Khan Market, New Delhi.

Sir,

This has a reference to MCD online application ID No. 2025092213640 dated 23/09/2025 on the subject cited above. In this connection, it is to inform you that officer concerned of this department has visited the premises on dated 09/10/2025 in presence of Manager and observed that the shortcomings as communicated earlier vide letter No. F.6/DFS/MS/EH/2022/477 dated 18/07/2022 (copy enclosed) have not been complied yet.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

29/10/25

Encl. As above

(A. K. MALIK)
DY. CHIEF FIRE OFFICER
ok 2. **DELHI FIRE SERVICE**

Copy to: -

MCD online Portal ID-2025092213640

C/42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/EH/2022/477 Dated: 18/7/2022

To,

The Commissioner, Excise Department,
GNCT of Delhi L Block, Vikas Bhawan,
IP Estate, New Delhi 110002 (Email dcexcise@nic.in)

Subject: Inspection report of M/s Wok in the Clouds (A Unit of Edesia Hospitality (P) Ltd.) Flat No.-22, 1st Floor & 2nd Floor, Khan Market, New Delhi

Sir,

Please refer to your MHA portal ID-2022050909770 dated 10/05/2022 on the subject noted above, in this connection, it is to inform you that the said premises was inspected by the officers concerned of this department on 09.07.2022 in the presence of Sh. Vipin Kumar and observed following shortcomings during the inspection:-

1. Only one staircase of width 1.00m is provided against requirement of 2 staircases of width 1.50mtr each.
2. MOEFA not provided.
3. Over Head Tank of 5,000 ltr is provided against requirement of 20,000 ltr capacity.

In view of above NOC/ FSC cannot be considered at this stage.

The occupancy of the building / premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner / occupier. The Licensing Authority / Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR.

Copy to:-

1. Addl. Commissioner of Police (Lic), 1st Floor, PS defence colony, New Delhi-110049.
2. M/s Wok in the Clouds (A Unit of Edesia Hospitality (P) Ltd.) Flat No.-22, 1st Floor & 2nd Floor, Khan Market, New Delhi